

排ガス測定結果

四日市市

施設名称 北部清掃工場  
測定(採取)位置 煙道測定口

月	測定年月日	結果を得た年月日	ばいじん* (g/m <sup>3</sup> N)			塩化水素* (mg/m <sup>3</sup> N)			硫黄酸化物 (K値)			窒素酸化物* (ppm)			ダイオキシン類* (ng-TEQ/m <sup>3</sup> N)			水銀* (mg/m <sup>3</sup> N)		
			1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
			法規制値 = 0.08			法規制値 = 700			法規制値 = 1.17			法規制値 = 300		250	法規制値 = 1.0					
4月	H23.4.27	H23.5.18	0.005未満	-	0.005未満	13未満	-	12未満	0.011	-	0.021	88	-	74	-	-	-	-	-	-
5月	H23.5.18	H23.6.8	-	0.005未満	0.005未満	-	12未満	-	-	0.015	-	-	74	-	-	-	-	-	-	
6月	H23.6.17	H23.7.7	0.005未満	-	0.005未満	12未満	-	12未満	0.055	-	0.025	88	-	59	-	-	-	-	-	
7月	H23.7.5	H23.7.26	-	0.005未満	0.005未満	-	12未満	-	-	0.062	-	-	77	-	-	-	-	-	-	
8月	H23.8.22	H23.9.8	0.005未満	-	0.005未満	12	-	11未満	0.042	-	0.032	81	-	45	-	-	-	-	-	
	H23.8.10	H23.9.13															0.000064		0.0011未満	
	H23.8.11	H23.9.13													0.000095			0.0009未満		
	H23.8.12	H23.9.13															0.00017		0.0008未満	
9月	H23.9.7	H23.9.27	-	0.005未満	0.005未満	-	11未満	-	-	0.035	-	-	75	82						
10月	H23.10.6	H23.10.27	0.005未満	-	0.005未満	12未満	-	11未満	0.11	-	0.041	75	-	65	-	-	-	-	-	
11月	H23.11.9	H23.11.29	-	0.005未満	0.005未満	-	13未満	-	-	0.025	-	-	73	82	-	-	-	-	-	
12月	H23.12.12	H23.12.26	0.005未満	-	0.005未満	16	-	13未満	0.012	-	0.018	81	-	58	-	-	-	-	-	
1月	H24.1.5	H24.1.23		0.005未満	0.005未満	-	12	-	-	0.014	-	-	75	71	-	-	-	-	-	
2月	H24.2.20	H24.3.12	-	0.005未満	0.005未満	-	22	11未満	-	0.049	0.05	-	84	60						
	H24.1.6	H24.2.17															0.000084		0.0008未満	
	H24.1.10	H24.2.17														0.000097		0.0008未満		
	H24.1.11	H24.2.17													0.000086			0.0008未満		
3月	H24.3.8	H24.3.28	0.005未満	-	0.005未満	12未満	-	-	0.037	-	-	68	-	55	-	-	-	-	-	

\*測定値は酸素補正值(12%換算)