

排ガス測定結果

四日市市

施設名称 北部清掃工場  
測定(採取)位置 煙道測定口

月	測定年月日	結果を得た年月日	ばいじん* (g/m <sup>3</sup> N)			塩化水素* (mg/m <sup>3</sup> N)			硫黄酸化物 (K値)			窒素酸化物* (ppm)			ダイオキシン類* (ng-TEQ/m <sup>3</sup> N)			水銀* (mg/m <sup>3</sup> N)		
			1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
			法規制値 = 0.08			法規制値 = 700			法規制値 = 1.17			法規制値 = 300		250	法規制値 = 1.0					
4月	H24.4.19	H24.5.10	0.005未満	-	0.005未満	19	-	24	0.034	-	0.062	68	-	34	-	-	-	-	-	-
5月	H24.5.10	H24.5.30	-	0.005未満	0.005未満	-	15	-	-	0.051	-	-	76	43	-	-	-	-	-	-
6月	H24.6.27	H24.7.18	0.005未満	-	0.005未満	10	-	17	0.035	-	0.065	82	-	77	-	-	-	-	-	-
7月	H24.7.23	H24.8.13	-	0.005未満	0.005未満	-	6未満	-	-	0.069	-	-	82	40	-	-	-	-	-	-
8月	H24.8.22	H24.9.11	-	0.005未満	0.005未満	-	15	28	-	0.039	0.034	-	81	35	-	-	-	-	-	-
	H24.8.1	H24.9.18	-	-	-	-	-	-	-	-	-	-	-	-	-	0.000091	-	-	0.003未満	-
	H24.8.2	H24.9.18	-	-	-	-	-	-	-	-	-	-	-	-	0.00013	-	-	0.005	-	-
	H24.8.3	H24.9.18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0.000071	-	-	0.003未満
9月	H24.9.21	H24.10.12	0.005未満	-	0.005未満	32	-	-	0.021	-	-	78	-	47	-	-	-	-	-	-
10月	H24.10.4	H24.10.17	0.005未満	-	0.005未満	28	-	19	0.021	-	0.021	78	-	55	-	-	-	-	-	-
11月	H24.11.12	H24.11.19	-	0.005未満	0.005未満	-	9	-	0.024	-	-	-	63	45	-	-	-	-	-	-
12月	H24.12.17	H24.12.27	0.005未満	-	0.005未満	12	-	17	0.033	-	0.029	76	-	55	-	-	-	-	-	-
1月	H25.1.21	H25.1.29	-	0.005未満	0.005未満	-	10	-	-	0.028	-	-	80	51	-	-	-	-	-	-
2月	H25.2.1	H25.2.13	-	0.005未満	0.005未満	-	16	11	-	0.033	0.022	-	82	62	-	-	-	-	-	-
3月																				

\*測定値は酸素補正值(12%換算)