

施設名称 北部清掃工場  
 測定(採取)位置 煙道測定口

月	測定年月日	結果を得た年月日	ばいじん* (g/m <sup>3</sup> N)			塩化水素* (mg/m <sup>3</sup> N)			硫黄酸化物 (K値)			窒素酸化物* (ppm)			ダイオキシン類* (ng-TEQ/m <sup>3</sup> N)			水銀* (mg/m <sup>3</sup> N)		
			1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
			法規制値 = 0.08			法規制値 = 700			法規制値 = 1.17			法規制値 = 300		250	法規制値 = 1.0					
4月	H26.4.24	H26.5.15	0.005未満	-	0.005未満	21	-	13	0.022	-	0.0071	74	-	73	-	-	-	-	-	-
5月																				
6月																				
7月																				
8月																				
9月																				
10月																				
11月																				
12月																				
1月																				
2月																				
3月																				

\*測定値は酸素補正值(12%換算)